

Duration Three Hours

Date: May 02nd 2006

Time: 0930-1230 hrs.

This paper contains Eight (8) questions. Answer any five (5). All questions carry equal marks. Graph papers will be available on your request.

1. The flux Φ linked by a coil of 100 turns varies during the period T of one complete cycle as follows;

$$\text{From } t = 0.0 \text{ to } t = T/2, \quad \Phi = \Phi_m \left(1 - \frac{4t}{T} \right); \quad \text{and}$$

$$\text{From } t = T/2 \text{ to } t = T, \quad \Phi = \Phi_m \left(\frac{4t}{T} - 3 \right).$$

If T be $1/50$ sec., and Φ_m be 2 mega lines, calculate the maximum value of the induced electromotive force. Plot to scale the flux and electromotive force waves.

(Assume that 10^8 mega lines = 1 wb)

2. Two domestic consumers "A" & "B" are fed by a certain local electricity supply metered at 400V/230V. Variation of their daily load patterns (including week-ends & holidays) are as given below:

Consumer A

| | | | | |
|------|-----------|----|-----------|---------|
| From | midnight | to | 7.00 a.m. | 250 W |
| | 7.00 a.m. | to | 6.00 p.m. | No load |
| | 6.00 p.m. | to | 7.00 p.m. | 2500 W |
| | 7.00 p.m. | to | 9.00 p.m. | 4000 W |
| | 9.00 p.m. | to | mid night | 500 W |

Consumer B


| | | | | |
|------|------------|----|------------|---------|
| From | midnight | to | 9.00 a.m. | 500 W |
| | 9.00 a.m. | to | 12.00 noon | 200 W |
| | 12.00 noon | to | 5.00 p.m. | 700 W |
| | 5.00 p.m. | to | 7.00 p.m. | No load |
| | 7.00 p.m. | to | mid night | 3500 W |

- Plot the load variation during 24 hours for each consumer?
- Hence find out the maximum and minimum demand for each consumer?
- Plot the total load variation during 24 hours and hence find the maximum power that has to be delivered by the electric supplier
- Compute the energy consumption by each consumer, and hence prepare the monthly electricity bill for each consumer (You may use the attached tariff table for the computation of monthly electricity charges)

3. The efficiency, at unity power factor (p.f.=1), of a 6600/384 V, 200 kVA, single phase transformer is 98% both at full-load and half-load. The power factor on no-load is 0.2. The full-load regulation at a lagging-power factor of 0.8 is 4%. Draw the equivalent circuit referred to the low voltage side and show all the values of the parameters.

Hint: You may neglect the magnetizing branch when doing the voltage reg. calculation.

$$\text{Also assume that } \left[\text{Voltage regulation} = \frac{V_s - V_R}{V_s} \approx \frac{I.R.\cos\phi + I.X.\sin\phi}{V_s} \right]$$



- (a) Calculate the inductance per phase per km of the above 132 kV transmission line conductor configuration. Conductor radius is 2 mm.
- (b) Calculate the equivalent radius of a conductor for each phase which would give the same value as in part (a) for the inductance, if the single conductors are to be placed at the centre points of the present double conductors.
5. Three 1Φ loads are connected to a 2000 kVA transformer as shown below in fig. Q5. Copper loss and iron loss when delivering the rated power are 40 kW and 22 kW respectively. Behavioral pattern of the loads connected to the transformer during a normal working day is given in table Q5.




Fig. Q5

Table Q5

| Time | Load-1 (P1) | | Load-2 (P2) | | Load-3(P3) | |
|------------------------|-------------|---------------|-------------|---------------|------------|---------------|
| | P(kW) | cos(ϕ) | P(kW) | cos(ϕ) | P(kW) | cos(ϕ) |
| 6.00 a.m. - 12.00 noon | 400 | 0.8 | 100 | 0.75 | 300 | 0.9 |
| 12.00 noon - 4.00 p.m. | 600 | 0.9 | 300 | 0.85 | 450 | 0.95 |
| 4.00 p.m. - 9.00 p.m. | 250 | 0.9 | 400 | 0.95 | 700 | 1.00 |

6. A suspension insulator string is shown in Fig Q6 together with its associated capacitances. The conductor voltage is V .

Calculate the voltage distribution and string efficiency under the following conditions:

- (a) $C_1 = C_2 = C_3 = C_4 = 10 \text{ C}$
 (b) $C_1 = C_2 = 15 \text{ C}$ and $C_3 = C_4 = 10 \text{ C}$

Comment on the above results.




Fig. Q6

7. Find ABCD constants of a nominal π network model of a transmission line. A 3Φ , 50 Hz, 100 km overhead transmission line has the following line constants per km.

Resistance = 0.153Ω inductance = 1.21 mH capacitance = $0.00958 \mu\text{F}$

The line supplies a load of 20 MW at 0.9 power factor lagging at a line voltage of 110 kV at the receiving end. Using a nominal π representation, calculate sending end voltage, current, power factor, voltage regulation and efficiency.

8. A 3Φ , 500 V, 50 cycles/sec induction motor with 6 poles develops 20 h.p at 950 rev/min with a power factor of 0.86. The mechanical losses totals 1 h.p. calculates for this load:
- The motor slip (s)
 - The rotor copper loss
 - The input power to the motor, if the stator (wdg. + core) losses is 1500 Watts
 - The line current.

(Assume 746 watts = 1 hp)

Tariff table for Q2

| Customer Category | Conditions | Maximum demand charge Rs./kVA per month | Energy Charge Rs./kwh | Fixed Charge Rs./month |
|--|---|---|--|------------------------|
| Domestic | Metered at 400V/230V | - | 0-30 Units @ 3.00 31-60 Units @ 3.70 61-90 Units @ 4.10 91-180 Units @ 10.60 Above 180 Units @ 15.80 | 30.00 |
| Religious | Metered at 400V/230V | - | 0-30 Units @ 2.50 31-90 Units @ 2.70 91-180 Units @ 4.00 Above 180 Units @ 7.20 | 30.00 |
| General Purpose All buildings except industries & some hotels | Metered at 400V/230V contract demand < 42 kVA Demand up to 10 kVA Demand above 10 kVA | - | 10.90 10.90 | 30.00 230.00 |
| | contract demand > or = 42 kVA Metered at 400V/230V Metered at 11/33/132 kV | 480.00 460.00 | 10.80 10.70 | 800.00 800.00 |
| Industrial Includes some hotels | Metered at 400V/230V contract demand < 42 kVA Demand up to 10 kVA Demand above 10 kVA | - | 7.50 7.50 | 30.00 230.00 |
| | contract demand > or = 42 kVA Metered at 400V/230V Metered at 11/33/132 kV | 400.00 380.00 | 7.10 7.00 | 800.00 800.00 |
| Industrial Time Of Day Includes some hotels | Metered at 400V/230V contract demand < 42 kVA Demand up to 10 kVA Demand above 10 kVA | - | 15.00 bet 7-10 p.m. 6.90 at other times | 30.00 230.00 |
| | Metered at 400V/230V contract demand > or = 42 kVA | 380.00 | 14.70 bet 7-10 p.m. 6.50 at other times | 800.00 |
| | Metered at 11/33/132 kV contract demand > or = 42 kVA | 360.00 | 14.00 bet 7-10 p.m. 6.10 at other times | 800.00 |
| Supplies to licensees LECO/LA | Supply at 400/230 V | 240.00 | 7.20 | - |
| | Supply at 11k V & above | 220.00 | 5.40 | - |
| Standby Tariff | Supply at 400/230 V | 100.00 | 7.10 | 800.00 |
| | Supply at 11k V & above | 90.00 | 7.00 | 800.00 |
| Street Lighting | - | - | 7.80 | - |